GOVERNMENT OF JAMMU AND KASHMIR OFFICE OF THE JOINT DIRECTOR FIRE & EMERGENCY SERVICES, J&K. KASHMIR RANGE SRINAGAR

The Principal, Minto Circle English Medium High School/Sr. SecondrySchool, Allouchi Bagh Srinagar.

No: JDK/F-Prv/ 289

Dated. 16: 0/ : 2019

Subject: -

NOC.

Refince:- Your application No. 972/MCHSS Dated. 30-11-2018.

Sir,

In continuation to above referred letter on the captioned subject, the Provisional NOC is hereby revalidated for one year in favour of Minto Circle English Medium School/Sr, Secondry Allouchi Bagh Srinagar four storeyed school building in view of:-

- 1. Gate. 500 Cms.
- 2. Exits bilateral type. 185 (Two Nos.)
- 3. Corridor. 200 Cms.
- 3. Fire Extinguishers 02 No's in each floor.

However the case for final NOC shall be considered subject to having following provisions strictly as per NBC/BIS norms & specifications;-

- a) Hose reel at each floor with overhead tank having 10,000 liters & fire pump shall be installed in the building.
- b) Manually Operated Electric Fire Alram system.
- c) 4th floor (Huge Hall) shall not form part of school in view expected hazards that can be caused by extensive of timber and improper/inadequate escape routes.
- d) Fire Retardant Paint; Wooden components of the structures especially in attic portion shall be given fire retardant treatment of at least two hours rating.
- e) Precautions:-
 - All escape routes shall be kept free from any obstructions to provide hindrance free escape in case of emergency besides all doors, gates shall be kept unlocked during the occupancy of the school building.
 - Class/Halls have a capacity of more than 45 students shall have two exits. ii.
 - iii. Attic portion of the building shall not be used for any kind of storage.
 - Grill fitted in the windows shall be removed. iv.
 - Fire/Evacuation drill should be conducted regularly. V.
 - Employees of the school shall be trained for maintenance & use of Fire Vi. Fighting facilities.

Yours faithfully

Joint Director.

Fire & Emergency Services, J&K

Kashmir Range Sgr.