

Dated January 2016

Subject. No objection certificate (NO)

Refince - This office letter No. DDS/Es | 2644 Dated 14 12 2015

In continuation this office ab the referred to letter. It is kindly submitted that following fire fighting facilities have been provided for the school.

Exits:- School has Two stair cases one is centrally located and another is located exterior of the building which leads from ground floor to first floor.

First Aid Fire Fighting Equipments: "ire Extinguishers are installed in the school

Further it is submitted that all least one year time may be given to provide the remaining fire fighting facilities which shall include:-

- a) Alternative escape. The external stor case that presently goes from ground to first floor shall lead to top floor
- b) Hose reel at each floor with overheal, tank having 10,000 liters with fire pump and additional 50,000 liters water in shape of water reservoir within the premises shall be provided as school building is not accossible for fire tender.
- c) Fire retardant paint Wooden components of the structure especially in attic portion shall be given fire retardant paint of all least two hours rating
- It is pertinent to mention here that providing these facilities besides requiring structural improvisation / additional-ties ... so have financial implications.

The provisions for having emergency lights for exits of the school can be dispensed for the day use of schools. Excides all doors, shall be kept open during the school timings and the exits should be maintained to allow hindrance free escape in

In view of above, according, affiliation to the school may be extended for one year till the recommendations are in viemented and school is re-inspected for final clearance

Yours faithfully

Fire & Emergency Services, J&K.